

General Technical Requirements
for
Reference Designation, KKS Guideline
GTR-21

Doc. No./Version	Date	Prepared	Checked	Approved	Notes
1869549	11.04..2016	JNAD	SJEN	SOTP	

Table of contents

1	Scope and application.....	4
2	Reference designation basics	4
2.1	Introduction	4
2.2	Break down levels general	4
2.3	Reference designation structure	5
2.4	Reference designation block	6
2.5	Breakdown Level 0 "Unit"	6
2.6	Breakdown Level 1 "Function"	7
2.7	Breakdown level 2 "Equipment"	7
2.8	Breakdown level 3 "Component"	8
3	General rules	8
4	Structuring of numbering of process systems.....	9
4.1	Numbering	9
4.1.1	General	9
4.1.2	Geographically determined numbering.....	9
4.2	Decade numbering of process system	9
4.3	Numbering of 2-pipe systems.....	10
4.4	Numbering of boiler burners.....	11
4.5	Functional systems involving several functions	11
4.6	KKS numbering using typical diagrams	12
4.7	Instrumentation	13
4.7.1	Piping and instrumentation interfaces.....	13
4.7.2	Differential pressure measurement.....	13
5	Representation of reference designation in diagrams.....	14
5.1	General.....	14
5.2	Reference designation for connections	14
5.3	Representation of change of reference designation for connections	15
5.4	Reference designation for measuring points	15
5.5	Letter codes for measurement points	15
6	Designation of cables.....	15
6.1	Numbering system	15
6.2	Marking of cables.....	16
6.3	Numbering rules and examples.....	16
7	Designation of signals	17
8	Creation of denominations	18
8.1	General.....	18
8.2	Foreign and Danish suppliers.....	18
8.3	Structuring of text strings	18
8.4	Maximum length of denominations, text fonts, etc.....	19
8.5	Abbreviations	19

Annex	Page
Annex A Letter codes and numbering of equipment	21
Annex B Letter codes for components	27
Annex C Signals	30
Annex D Letter codes for process variables and control functions	38

Reference documents

ISO 14084-1	Process diagrams for power plants Part 1: Specification for diagrams
ISO 15519-2	Specifications for diagrams for process industry Part 2: Measurement and control
VGB B101e	Reference Designation System for Power Plants, RDS-PP Letter Code for Power Plant Systems (System Key), Edition 3, 2011
VGB B105e	KKS Identification System for Power Plants Guideline for Application and Key Part, Index A, B, C + D, Edition 7, 2010
VGB B106A e	KKS-Application Explanations. Part A KKS-Identification System for Power Stations, Edition 2004
VGB B108	Rules for the creation of denominations and their application for power plant engineering
GTR-3	Documentation
GTR-16	Marking and labeling
Annex-10	Reference designation, KKS letter codes for functions

1 Scope and application

This General Technical Requirement (GTR-21) specifies rules and guidelines for:

- Use of reference designation in diagrams
- Creation of designations and denominations of technical objects
- Technical object designation for equipment, components and signals within civil, process, mechanical, electrical, instrumentation and control systems.
- Letter codes for identification of measured values and their application within process control.

Functional designations for objects are specified in plant specific documents.

The use of reference designation, for identification / numbering of documents, is described in GTR-03: Documentation.

The use of reference designation, for marking and labelling of components, is described in GTR-16: Marking and labelling.

Identification of geographic location of objects is given as data attached to the technical object designation. Specifications for creation of data set for geographical location will be given in a plant specific document.

2 Reference designation basics

2.1 Introduction

Reference designation described in this GTR-21 is based on VGB publications: "B106e:2004 KKS Application Explanations" and the Employer's general practice for reference designation in power plant units.

This means that reference designation described in this GTR-21 is not in strict coherence with the official VGB guideline B106e, but represents a merge of the official guidelines and the Employer's general practice.

2.2 Break down levels general

A reference designation code for a technical object is a hierarchic alphanumeric structure with following four breakdown levels with increasing detailing in order to classify and unequivocally identify the object:

- Unit
- Function
- Equipment
- Component

Table 1 illustrates the breakdown of the reference designation for object "AMV04 LAB10AA001-M01", which "decoded" is an electrical actuator (-M01), for a valve (AA001), in feed water system (LAB10), in unit (AMV04).

Table 1 - Illustration of the four breakdown levels for an object

Level	Unit	Function	Equipment	Component
Unit	AMV04			
Function		LAB10		
Equipment			AA001	
Component				-M01

The understanding of the function, equipment and component aspects are essential for practical use of reference designation in general and creation of correct reference designation for an object.

Figure 1 shows the breakdown systematics for a typical process system from function to component level.




Figure 1 - Illustration of break down levels in a process system

2.3 Reference designation structure

The reference designation system allows creation of reference designation codes for practical application on different levels. Table 2 shows possible reference designation codes.

Table 2 – Possible reference designation codes for technical objects

Breakdown level	Reference designation code	Description
Unit	AMV04	Unit 04
Function	AMV04 L	Unit 04, Steam, water, condensate systems
	AMV04 LA	Unit 04, Feed water system
	AMV04 LAB	Unit 04, Feed water piping system
	AMV04 LAB10	Unit 04, Feed water piping system 10
Equipment	AMV04 LAB10AA001	Unit 04, Feed water piping system 10, valve AA001
Component	AMV04 LAB10AA001 –M01	Unit 04, Feed water piping system 10, valve AA001, electrical actuator –M01

The letter code string of a full reference designation shall have spaces as illustrated with underscore in following example: AMV04_LAB10AA001_-M01.

OBS: The underscore signs are only for illustration, not part of the of the reference designation.

2.4 Reference designation block

A reference designation code has a hierarchic alphanumeric structure with up to four breakdown levels with increasing level of detailing in order to classify and unequivocally identify all objects.

The structure of a reference designation block is illustrated in Figure 2.

Beak down level	0	1			2			3	
Designation	Unit	Function			Equipment			Component	
Alphanumeric characters	AAANN	(N)	AAA	NN	AA	NNN	A	AA	NN
(Reference)	1	2	3	4	5	6	7	8	9

A = Letters, N = Digits

Figure 2 - Structure and break down of a reference designation block

2.5 Breakdown Level 0 "Unit"

This breakdown level defines the various units or common systems not belonging to a specific unit, within a power plant.

Breakdown level 0 for unit – see figure 3 - is composed of following elements:

AAANN (ref 1) Letter / digit coding of units.

Break down level	0	1	2	3
Designation	Unit	Function	Equipment	Component
Alphanumeric characters	AAANN	(N) AAA NN	AA NNN A	AA NN
(Reference)	1	2 3 4	5 6 7	8 9

Figure 3 - Structuring of break down level 0: Unit

If no confusion can arise, the unit designation break down level 0, can be omitted.

In documents with reference designation from two or more units, the in front unit designation, break down level 0 reference, shall always be used.

2.6 Breakdown Level 1 "Function"

Breakdown level 1 for function – see figure 4 - is composed of following elements:

(N) (ref 2) 1-digit coding. Applies only in case of two or more main systems within a unit e.g. two parallel boilers. If not used (N) (ref 2) shall be omitted.

AAA (ref 3) 3-letter coding of functions, which is defined in a plant specific document.

NN (ref 4) 2-digit serial numbering, which is described in this document

Break down level	0	1	2	3
Designation	Unit	Function	Equipment	Component
Alphanumeric characters	AAANN	(N) AAA NN	AA NNN A	AA NN
(Reference)	1	2 3 4	5 6 7	8 9

Figure 4 - Structuring of break down level 1: Function

The 3 letters (ref 3) constitute a function specific subdivision of the overall unit into functional process systems, auxiliary systems or building structures.

2.7 Breakdown level 2 "Equipment"

Breakdown level 2 for equipment – see figure 5 - is composed of following elements:

AA (ref 5) 2-letter coding of equipment, which is defined in Annex A.

NNN (ref 6) 3-digit serial numbering, which is defined in Annex A

A (ref 7) 1-letter coding of additional equipment information e.g. manually operated valves with limit switches, where A=open and B=closed position.

If not used, A (ref 7) can be left out.

A (ref 7) must not be used, if the object is assigned a typical diagram – see section 4.6 for application of typical diagrams.

Break down level	0	1			2			3	
Designation	Unit	Function			Equipment			Component	
Alphanumeric characters	AAANN	(N)	AAA	NN	AA	NNN	A	AA	NN
(Reference)	1	2	3	4	5	6	7	8	9

Figure 5 - Structuring of break down level 2: Equipment

For manually operated valves, dampers etc. with limit switches, the serial number (ref 6) in the reference designation for the limit switches shall be the same as for the object (valve, damper) they are part of.

2.8 Breakdown level 3 “Component”

Breakdown level 3 for components – see figure 6 - is composed of following elements:

AA (ref 8) 2-letter coding of components, which are defined in Annex B.

For electro-technical components the first letter is replaced by a dash "-"

NN (ref 9) 2-digit serial numbering

Break down level	0	1			2			3	
Designation	Unit	Function			Equipment			Component	
Alphanumeric characters	AAANN	(N)	AAA	NN	AA	NNN	A	AA	NN
(Reference)	1	2	3	4	5	6	7	8	9

Figure 6 - Structuring of break down level 3: Component

3 General rules

Establishment of a reference designation structure for a process plant or process system is based on a sequential break down process with following main topics:

- Identification of functional systems – 1. letter in the functional designation "AAA (ref 3)"
- Identification of interface limits between functional systems
- Identification of functional sub systems - 2. and 3. letter in the functional designation "AAA (ref 3)"
- Identification of interface limits between functional sub-systems
- Numbering of functional sub-systems following the decade or serial concept, depending of the complexity of the individual systems

The decided reference designation structure down to numbered functions and their interface limits shall be documented in process flow diagrams (PFD) each covering 1. letter functional systems.

4 Structuring of numbering of process systems

4.1 Numbering

4.1.1 General

The number elements of the breakdown level references (ref 4), (ref 6) and (ref 9) have a numbering (counting) structure to be used in one or more of the following ways:

- The numbering starts once more when one of the preceding underlined letter codes, (ref 3) AAA, (ref5) AA or (ref 8) AA changes.
- The numbering can be consecutive or grouped.
- Preceding zero-digits must be written.
- 00 and 000 shall not be used for serial numbering
- later addition of sub-systems e.g. within a decade should be taken into account

4.1.2 Geographically determined numbering

In case when the flow direction does not provide an unequivocal rule of numbering, the numbering shall follow the geographical numbering rules given in below:

Priority 1: Down → Up
 Priority 2: South → North
 Priority 3: West → East

4.2 Decade numbering of process system

Numbering of process systems shall predominant follow the decade principle.

Structuring using the decade concept must consider the number of available decade in order to obtain a logical / easy recognizable structure,

In figure 7 is illustrated decade numbering of a process system consisting of two functional group each consisting of three pumps and three heaters. These functions are numbered continuously within the decades. This numbering concepts contributes to establish logical and recognizable groups.

Numbering within a decade shall follow the serial numbering concept – see figure 8.




Figure 7 - Example of decade numbering

The above numbering concept can be used for functions, which have no associated auxiliary sub-functions.

Numbering of pump groups, where the individual pumps can have associated sub-equipment, must be made with decade numbering as illustrated in figure 8. This concept gives "numbering space" for up to nine sub-functions for each pump.




Figure 8 - Example of decade numbering to allow numbering space for pump sub-systems

4.3 Numbering of 2-pipe systems

In 2-pipe systems e.g. closed cooling water system, the valves in forward and return for a heat exchanger shall be numbered with same equipment number e.g. PGA31 and PGB31 – see figure 9.




Figure 9 Example of numbering of circulation systems

4.4 Numbering of boiler burners

Burners shall be numbered to secure a logical relation between the fuel firing systems and related fuel injection systems / burners. Figure 0 illustrates eight burners organized in four elevations. The numbering follows the rules: Down → up and West → east.




Figure 10 Numbering of burners in a boiler

4.5 Functional systems involving several functions

Functional systems e.g. heat exchangers, which have functional relations to auxiliary heating or cooling systems, shall be numbered, as part of their main / auxiliary systems to which they belong – see figure 11.




Figure 11 Numbering of a functional system involving several functions

4.6 KKS numbering using typical diagrams

Typical diagrams (TYD) are used for structuring and standardizing of the interfaces between process objects controlled by the DCS system and / or includes an electrical motor or electrical actuator.

Objects in a typical are designated reference designation on component level. A table of reference designations will indicate which objects shall be registered in the database and which shall be provided with component tag according to GTR-16.

For a process object e.g. an on-off valve with pneumatic actuator a coherent set of typicals are prepared consisting of:

- a mechanical typical showing the objects with interface to the DCS system and to the instrument air supply
- a DCS typical showing the wiring to the DCS system (hard wired or Profibus)

For a process object e.g. an on-off valve with electrical actuator the set of typicals will consist of:

- a mechanical typical showing the objects with interface to the DCS system and electrical supply (MCC)
- a DCS typical showing the wiring to the DCS system (hard wired or Profibus)
- an electrical typical showing the wiring to the MCC and to the DCS system

For a process measurement points (instrumentation) the set of typical will consist of:

- a combined typical and hook-up drawing showing the objects with interfaces to DCS system and eventually electrical supply.
- a DCS typical showing the wiring to the DCS system (hard wired or Profibus)

- an electrical typical showing the wiring to the MCC and to the DCS system

The coherence between a set of mechanical, DCS and/or electrical typicals, is secured by using same document serial number.

DCS and electrical typicals are used for wiring and choice of interfaces to DCS and MCC systems.

The in force collection of typicals for a specific project will be made available for the Contractors, shortly after signing of agreements.

If need for a new typical the Contractor shall submit a draft to the project groups in charge of the DCS and MCC systems, who will approve the proposal and made in force for the project.

4.7 Instrumentation

4.7.1 Piping and instrumentation interfaces

Interface between piping and instrumentation shall be numbered as follows – see Figure 22:

Temperature measurement: Thermowell belongs to instrumentation. Reinforcement boss belongs to piping – see figure 12A

Pressure measurement: Instrument root valve belongs to piping – see figure 12B

Inline instrument devices The inline instrument device e.g. venturi nozzle, is part of measurement point. Instrument root valves are numbered as part of piping - see figure 12 C





Figure 22 Numbering of piping / instrument interfaces

4.7.2 Differential pressure measurement

Differential pressure measurements include two separate measuring points.

If the measurement is within the same function, transmitter and instrument root valves are numbered in the same function – see Figure 33A.

If the measurement is across two functions, transmitter is numbered in the function with the lowest alphanumeric number. The instrument root valves are numbered in accordance with the functions they branch off from – see Figure 33B



A: Diff. pressure measurement within same function

B: Diff. pressure measurement across two functions

Figure 33 Numbering of differential pressure measurements

5 Representation of reference designation in diagrams

5.1 General

Display of reference designation in process diagrams are described in ISO14084-1. Specific rules for representation of measurement and control are given in ISO 15519-2.

Function and equipment designations must be numbered in the flow direction of the process.

In process diagrams (PID) technical objects shall be represented with reference designation down to equipment level. If an equipment consists of 2 or more components essential for understanding of functionality of the equipment, representation in a detailed PID may be necessary. This rule does not apply for e.g. an electrical operated pump, where it is evident, that electrical motor as component will have a reference designation ending with "-M01"

In typical diagrams (TYD) technical objects shall be represented only with component reference designation.

A reference designation text string shall be a single line and oriented horizontally or vertically corresponding to the reading directions viewed from the bottom edge or viewed from the right-hand edge of the document.

5.2 Reference designation for connections

Representation of reference designation for connections e.g. pipes and ducts, shall be made by using flags – see Figure 14. The "flag" principles is described in ISO 14084-1 Annex D

The pointing direction of the flag indicates the flow direction.

In case of reversible flow, flag type as for GCK10BR001 – see Figure 14 - , shall be used.

The flags shall be placed in the beginning of the connection and at regular intervals

The equipment reference for connections (BRxxx) shall be placed below the flag as illustrated in Figure 14.

5.3 Representation of change of reference designation for connections

Change of functional reference designation for process connections e.g. pipes and ducts in diagrams shall be marked with open pushpins – see figure 14.

Change of equipment reference designation for process connections e.g. pipes and ducts in diagrams shall be marked with closed pushpins – see figure 14.

Rules for design and application of pushpins are given in ISO 14084-1 Annex A.




Figure 14 - Representation of changes of RD for connections in diagrams

5.4 Reference designation for measuring points

Reference designation for measuring points shall be displayed in the lower part of Process Control Symbols (PCI) as shown in ISO 15519-2. Figure 13 shows application of PCI symbols for measuring points.

5.5 Letter codes for measurement points

Letter codes for measured values and their application in process control are displayed in the upper part of the PCI symbol – see figure 13.

Overview of letter codes for measured variables and for application of measured variables for process control (control functions) are specified in Annex D.

6 Designation of cables

6.1 Numbering system

Cables are numbered with a reference designation system deviating from numbering of process components.

For cable numbering only the unit designation and the alphabetic part of the function designation are used followed by a four digit number, as illustrated in **Figure 45**.

- A/N (ref 1) Letter / digit coding of units. The designation of units within a plant are specified in a separate document
- (N) (ref 2) 1-digit coding. Applies only in case of two or more main systems within a unit e.g. two parallel boilers. If not used (N) (ref 2) shall be omitted.
- AAA (ref 3) 3-letter coding of functions. The letter codes are defined in a plant specific document
- NNNN (ref 4) 4-digit serial numbering according to Table 3

Beak down level	0	1	2
Designation	Unit	Function	Cable number
Alphanumeric characters	A/N	(N) AAA	NNNN
(Reference)	1	2	3

Figure 45 Reference designation structure for cable numbering

Table 3 – Serial numbering of cables

Cable no.	Application	Voltage level
0001 – 0999	Power supply cables	> 1 kV
1001 – 1999	Power supply cables	< 1 kV
2001 – 2999	Measuring cables	> 60 V
3001 – 3999	MCC, coupling relays	< 60 V
4001 – 4999	Interconnecting cables between cabinets	
5001 – 5999	Actuator feedback cables	
6001 – 6999	Cables from junction boxes	
7001 – 7999	Interconnecting cables between cabinets and consoles	
8001 – 8499	- free for use -	
8501 – 8599	Supply cables for solenoids	24 V DC
8601 – 8999	- free for use -	
9001 – 9999	Special cables e.g. bus, network, communication – e.g. fiberoptic and copper	

6.2 Marking of cables

Cable shall be marked with reference designation and type, as specified in GTR-16: Marking and labelling.

6.3 Numbering rules and examples

Following rules apply for numbering of cables:

- Cables between two objects shall be numbered with the function code for the object designated first in the alphabet.
- Power cables between electrical supply systems are numbered according to the power direction.
- Connecting cables to instrument transmitters shall be numbered according to the instrument transmitter.

Examples of cable numbering are given in **Figure 56** and Figure 67




Figure 56 Cable numbering for a pulverizer




Figure 67 - Cable numbering for instrument transmitters

Rules for labeling of cables e.g. specification of information in the label, placement of labels, etc. are given in GTR-16.

7 Designation of signals

Letter codes for numbering of signal designation in the application software are specified in Annex C.

It is an advantage to follow these rules, despite former projects not are consistent in this subject.

8 Creation of denominations

8.1 General

KKS designated objects must be assigned a denomination, which gives a representative description of the main characters of the object.

Denominations must be prepared for use in all plant operation and management systems, where KKS reference designations are used as reference. Examples of operation and management systems, where KKS denominations are used, are e.g. KKS object data bases, documentation data bases, maintenance management systems, screen presentation, component tags, etc.

Correct denomination of KKS designated objects are crucial for the communication within engineering, operation, maintenance in all life cycle phases. Therefore, the creation of denominations for KKS designated objects must be given the utmost attention.

This section specifies rules for creation of denominations for KKS designated objects, which among others include:

- Structuring of text strings
- Length of text strings, text fonts
- Abbreviations
- media designations

8.2 Foreign and Danish suppliers

Denominations shall be in Danish language.

Foreign suppliers may prepare denominations in English language. The denominations shall be without abbreviations.

Employer will translate the English denominations into Danish and return them to Contractor add them to EDH

Supplier shall use Danish denominations in all documentation.

Danish suppliers shall prepare denominations in Danish language following below rules.

8.3 Structuring of text strings

Denominations are composed of four element terms as illustrated in table 4.

It is not mandatory that all elements are represented in a denomination, which appears in table 4.

Table 4 – Elements of a denomination

Element term	Source	Arrangement	Reference	Condition
	PRESSURE	BEFORE	PUMP 21	HIGH

Examples	CHECK VALVE	AFTER	BOOSTERPUMP A	
	TEMPERATURE		HEATER 22	LOW

The four elements are described below:

Source term

The **source term** represents the object / aspect , that the denomination concerns, e.g.

- Physical object, e.g. pump, valve
- Functional object, e.g. controller
- Physical quantity, e.g. pressure, temperature, flow

Arrangement term

The **arrangement term** describes the logic/systematic correlations between the **source term** and the **reference term**, e.g.

- Suction / pressure side
- Forward / return flow
- Before / after
- Inside / outside

Reference term

The **reference term** is an unambiguous identification of the object to which the **source term** concern

- Physical object e.g. pump, fan, vessel

Condition term

The **condition term** describes the condition / property of the **source term**

- Measured value
- Limit value(min / max, on / off)
- Position (open / closed)

8.4 Maximum length of denominations, text fonts, etc.

The maximum length of a denomination – in Danish language – is 28 characters incl. word spacing.

Denominations shall be with capital letters.

8.5 Abbreviations

The use of abbreviations shall be minimized.

Dots shall be used to identify an abbreviation, when the abbreviation appears inside the text string. If the abbreviation appears as the last text element, the dot must be omitted to save characters.

Employer has developed an abbreviation library – in Danish - for typical objects / aspects. The purpose of the standardized terms is to avoid abbreviation variants of same object / aspect.

For designation of measured values, the abbreviated designation in table 5 shall be used

Table 5 – Abbreviated designations for measured values

UK Measured variable	DK Målt art	UK Abbreviation	UK Unit
	DK Forkortelse	DK Enhed	
Current (electrical)	Strøm (elektrisk)	STR	A
Voltage (electrical)	Spænding (elektrisk)	SP	V
Resistance (electrical)	Modstand (elektrisk)	MODST	ohm
Power (electrical)	Effekt (elektrisk)	EFFEKT	W
Energy (heat)	Effekt (varme)	EFFEKT	J/s
Flow	Flow	FLOW	kg/s el. Nm ³ /h
Speed	Hastighed	HAST	m/s
Temperature	Temperatur	TEMP	°C
Pressure gauge	Tryk overtryk	TRYK	barg
Pressure absolute	Tryk absolut	TRYK	bara
Pressure difference	Differenstryk	DIFTR	bar
Level	Niveau	NIVEAU	mm
Vibration (absolute)	Vibration (absolut)	VIBRA	mm/s
Vibration (relative)	Vibration (relativt)	VIBRA	µm
Expansion (thermal)	Ekspansion	EKSPA	mm
Salinity	Ledningsevne	LDEV	µS/cm
Particles	Partikel indhold	PARTIND	ppm
Carbon monoxide	Kulite	CO	% CO
Carbon dioxide	Kultveilte	CO ₂	% CO ₂
Acidity	Surhedsgrad	SURHGR	Ph
Oxygen	Iltindhold	O ₂	% O ₂
Speed	Omdrejninger	OMDR	o/min
Frequency	Frekvens	FREKV	Hz
Position (binary)	Position (binær måling)	POS	-
Position (analogue)	Stilling (analog måling)	STIL	%

Annex A Letter codes and numbering of equipment

A.1 Letter codes for equipment

A Mechanical equipment

(Components, which through movement or function influences the process)

- AA Valves, dampers, blinds including actuators, also manually operated valves
- AB Doors, sluices, etc. including drives
- AC Heat exchangers, heat transfer surfaces (se also AH)
- AD Not for use
- AE Turning, driving, lifting and slewing gear (also manipulators)
- AF Conveyors, feeders, escalators
- AG Generator units
- AH Heating, cooling and air conditioning units with integrated motors (see also AC)
- AJ Size reduction equipment, e.g. mills, grinders
- AK Compacting and packaging equipment for solid media
- AL Not for use
- AM Mixers, agitators
- AN Compressor units, fans, suction devices of all media except liquid media (see also AP)
- AP Pump units for liquid media (see also AN)
- AS Adjusting and tensioning equipment
- AT Extractors, cleaning, filtering, drying and separating equipment, e.g. soot blowers, shot cleaning system incl. steam traps, air release valves
- AU Converters, e.g. electro-hydraulic conversion gear, Voith gear (non electrical)
- AV Burners and other burner equipment, e.g. grates
- AW Stationary tooling, treatment equipment
- AX Test and monitoring equipment, e.g. a television, and carbon sampling device (not measuring circuits)
- AZ Special units

B Mechanical equipment

(Components in which the process takes place, is being stored or transported, and the carrying parts)

- BB Storage equipment, (tanks, vessels, condensing pots, standpipes, etc.)
- BE Shafts (only for erection and revision)
- BF Foundations
- BH Cooling and heating devices (not driven), e.g. heaters, cooling elements, steam heating of oil tanks, el-tracing etc.
- BN Ejectors, injector nozzles
- BP Throttle orifice, flow restrictors, limiters, orifices (not metering orifices). Burst discs, flame - and explosion arrestors
- BQ Hangers, supports, racks, piping penetrations
- BR Piping, ductwork, chutes, compensators, joints
- BS Silencers
- BT Flue gas catalytic converter modules
- BU Insulation, sheathing
- BY Controller
- BX Viewing glass
- BZ Special devices

C Direct measuring circuits

- CA Electric voltage
- CC Electric current
- CD Density
- CE Electric or electromagnetic variables (others than CA and CC)
- CF Flow
- CG Position, direction of rotation, distance, eccentricity, expansion
- CH Human observation
- CJ Power, energy
- CK Time
- CL Level
- CM Moisture, humidity
- CP Pressure
- CQ Quality measuring (pH-value, conductivity, viscosity, etc.)
- CR Radiation (radiation, light, nuclear, e.g. flame supervision)
- CS Velocity, frequency (mechanical), speed, acceleration,
- CT Temperature
- CU Combined variables

CW Weight, mass

CY Vibration

D Closed loop control circuits

DA Electric voltage

DC Electric current

DD Density

DE Electric or electromagnetic variables, others than DA and DC

DF Flow

DG Position, direction of rotation, distance, eccentricity, expansion

DH Human observation

DJ Power, energy

DK Time

DL Level

DM Moisture, humidity

DP Pressure

DQ Quality measuring (pH-value, conductivity, viscosity, etc.)

DR Radiation (heat radiation, light, nuclear, e.g. flame supervision)

DS Velocity, frequency (mechanical), speed, acceleration, vibration

DT Temperature

DU Combined variables

DW Weight, mass

DY Vibration

E Measuring value and signal conditioning (control blocks etc.)

EA General overall control

EB Group control

EC Sequence control

EG Unit control

EM EDP-CRT screen, terminal, TV camera

EN EDP printer

EP EDP - CPU

EQ EDP-magnet tape, cassette

ER Reactor protection

- EU Combined measuring value and signal conditioning
- EW Protection

F Indirect measuring circuits

- FA Electric voltage
- FC Electric current
- FD Density
- FE Electric or electromagnetic variables, others than FA and FC
- FF Flow
- FG Position, direction of rotation, distance, eccentricity, expansion
- FH Human observation
- FJ Power, energy
- FK Time
- FL Level
- FM Moisture, humidity
- FP Pressure
- FQ Quality measuring (pH-value, conductivity, viscosity, etc.)
- FR Radiation (radiation, light, nuclear, e.g. flame supervision)
- FS Velocity, frequency (mechanical), speed, acceleration, vibration)
- FT Temperature
- FU Combined variables
- FW Weight, mass
- FY Vibration

G Electrical equipment

- GA Binary junction boxes (passive components)
- GB Analogue junction boxes (passive components)
- GC Combined junction boxes (passive components)
- GD Junction boxes
- GE Junction boxes
- GF Junction boxes, general
- GG Junction boxes, (penetrations, cables)
- GH Built-in units - as per process system (boxes for EL/DCS, larger E-motors)
- GK Information display and operator control equipment for process computers and automation systems

- GM Junction boxes for telecommunication services
- GP Junction box for lighting
- GQ Junction box/power sockets
- GR Batteries
- GS Box or panel including active components (switches), local operating box, local signal processing devices
- GT Transformers
- GU Converters
- GV Structure-related earthing and lighting protection for buildings, overvoltage protection isolators, earthing, circuit breakers
- GW Cabinet power supply equipment
- GX Actuating equipment for electrical variables
- GY Junction boxes for light-current systems (not of telecommunication services)

H Main and heavy machinery
(only in connection with function main groups M and X)

- HA Machine stationary assembly
- HB Machine rotating assembly
- HD Bearing assembly

A.2 Numbering of equipment

A.2.1 Valves, dampers, etc. with letter code AA

- AA001 – AA199 Valves, dampers for main piping and ducting
- AA201 – AA249 Valves in drain and flushing piping
- AA250 – AA299 Valves in venting piping
- AA301 – AA399 Valves for measurement points, instrument root valves
- AA401 – AA449 Valves for sampling extraction to analyser
- AA450 – AA499 Valves for chemical dosing
- AA501 – AA599 Valves for test functions
- AA601 – AA699 Valves for tracing
- AA701 – AA999 Valves for special purposes

A.2.2 Numbering of measurement points

- 001 – 199 Analogue and binary measurements to central control system (DCS)

201 – 299	Analogue and binary measurements to local control system, devices with signal processing e.g. flow and energy meter
301 – 399	Analogue and binary measurements with local instruments for visual value reading
401 – 499	Free for use
501 – 599	Gradient and material temperature measurements
601 – 699	Test measuring points
701 – 799	Free for use
801 – 899	Combined measurements for environment measurements
901 – 999	Combined or calculated measurements

Annex B: Letter codes for components

B.1 Mechanical components type "K"

KA	Gate valves, globe valves, dampers, taps, rupture disks, orifices
KB	Gates, doors, dam boards
KC	Heat exchangers, coolers
KD	Vessels/tanks, pools, surge tanks (fluid systems)
KE	Turning, driving, lifting and slewing gear
KF	Continuous conveyors, feeders
KG	Flanges, connections
KH	Heat pumps
KJ	Size reduction machines
KK	Compacting, packaging machines
KM	Mixers, agitators
KN	Compressors, blowers, fans
KP	Pumps
KT	Cleaning machines, dryers, separators, filters
KU	Power converters
KV	Burners, grates
KW	Stationary tooling and treatment machines for maintenance
KX	Stationary testing and supervision devices (inspection glass, inspection hole)
KZ	Special components

B.2 Mechanical components type "M"

MB	Brakes
MF	Foundations
MG	Gear boxes
MK	Clutches, couplings
MM	Motors, non-electrical
MR	Piping components, ductwork components
MS	Actuators non-electrical
MT	Turbines
MU	Transmission gear, non-electrical, converters and boosters other than couplings and gearboxes

B.3 Instrumentation and control components – non-electrical

- QB Sensors if not structurally integral with *QP*, e.g. metering orifices
- QH Signalling devices
- QN Controllers, flybolt governor
- QP Measuring instruments, testing equipment
- QR Instrument piping
- QS Condensation chambers (datum reservoir) in measuring circuits
- QT Thermowells and pockets for protection of sensors
- QU Converters (non-electrical)

B.4 Electrical components

- A Assemblies and subassemblies
- B Transducers for non-electrical to electrical values and vice versa
- C Capacitors
- D Binary elements, delay devices, memory devices
- E Lighting- and heating components, coolers etc., electrical heat tracing
- F Protective devices, fuses, limit switches
- G Generators, power supplies
- H Signalling devices
- J Mechanical devices for electrical equipment, cables, etc.
- K Relays, contactors
- L Inductors
- M Motors
- N Amplifiers, controllers, frequency converters
- P Measuring instruments, testing equipment
- Q Power switchgear
- R Resistors
- S Switches, selectors
- T Transformers
- U Modulators, convertors from electrical to other electrical variables
- V Tubes, semiconductors
- W Transmission paths, waveguides, aerials
- X Terminals, plugs, sockets
- Y Electrical positioners, e.g. solenoids (not motors)

- Z Terminations, balancing equipment, filters, limiters, cable terminations, equalizers, hybrid transformers

Annex C: Signals

C.1 Signal main groups

X	Signals to DCS (inputs)
Y	Signals from DCS (outputs)
Z	Combined signals

C.2 Signal origins (input values HW & SW) – type "X"

XA	Automatic signal / function group
XB	Single unit control
XC	Open loop control (analogue)
XG	Limit values, binary (contacts)
XH	High and low limit value, from an analogue signal
XJ	Analogue signals (from e.g. measurements)
XL	Low and high limit value, from analogue signal
XM	System acknowledge signals
XN	Binary acknowledge signals
XP	Process computer
XQ	Analogue signals (from e.g. measurements)
XR	Controller signals analogue
XS	Sequence step number
XT	Discharge signals
XU	Combined signals
XV	Fail Safe signals

C.3 Automatic signal / function group – type "XA"

XA01	Unit Switch Over On/Running
XA02	Unit Switch Over Off/Stopping
XA03	Unit Switch Over in Automatic
XA04	Unit Switch Over in Manual
XA05	Start-program selected
XA06	Stop-program selected
XA07	Start-program Running
XA08	Stop-program Running

XA11	Start signal for Sequence control
XA12	Stop signal for Sequence control
XA21	Equipment 1 start command
XA22	Equipment 2 start command
XA23	Equipment 3 start command
XA24	Equipment 4 start command
XA31	Equipment 1 Selected
XA32	Equipment 2 Selected
XA33	Equipment 3 Selected
XA34	Equipment 4 Selected
XA41	Equipment 1 stop command
XA42	Equipment 2 stop command
XA43	Equipment 3 stop command
XA44	Equipment 4 stop command
XA50	Error
XA51	Unit Switch Over not ON
XA52	Unit Switch Over not OFF
XA53	Unit Switch Over not in Auto
XA54	Unit Switch Over not in Manual
XAnn	Automatic signals free for use

C.4 Single drive control / Electrical-Valves / Motors – type "XB"

XB01	Drive control On / Open
XB02	Drive control Off / Closed
XB03	Drive control in auto
XB04	Drive control in manual
XB05	Drive control run Open / Direction 1
XB06	Drive control run Close / Direction 2
XB07	Drive control/Frequency converter ready
XB08	Drive control/Frequency converter error
XB09	Drive control stopped
XB10	Check back in Test position
XB11	Torque opening
XB12	Torque closing

XB16	Feedback Local operation
XB17	Feedback Remote operation
XB39	Feedback Thermal trip
XB49	Feedback Fault (common)
XB51	Feedback NOT STARTED/OPEN
XB52	Feedback NOT STOPPED/CLOSED

C.5 Controller – type "XC"

XC01	Valve/Damper open (100 %)
XC02	Valve/Damper close (0 %)
XC03	Valve/Damper in Automatic mode
XC04	Valve/Damper in Manual mode
XC05	Valve/Damper error
XC06	Torque in opening
XC07	Torque in closing
XC08	Remote control on
XC09	Local control on
XC10	Controller Auto up
XC11	Controller Auto down
XC13	Controller in Automatic
XC14	Controller in Manual
XC27	Command open
XC28	Command close
XC37	Emergency open
XC38	Emergency close
XC47	Release open
XC48	Release Close
XC51	Valve/Damper not open
XC52	Valve/Damper not closed

C.6 Binary transmitters / Contacts – type "XG"

XG01	NO/NC contact, >MIN
XG02	NO/NC contact, >MAX
XG51	NO/NC contact, <MIN

XG52 NO/NC contact, <MAX

C.7 Limit switches created from analogue signals – type "XH"

XH01 Limit Value greater than, >High1
 XH02 Limit Value smaller than, >Low1
 XH03 Limit Value greater than, >High2
 XH04 Limit Value smaller than, >Low2
 XH05 Limit Value greater than, >High3
 XH06 Limit Value smaller than, >Low3
 XH07 Limit Value greater than, >High4/MAX
 XH08 Limit Value smaller than, >Low4/MIN
 XH51 Limit Value NOT greater than, >High1
 XH52 Limit Value NOT smaller than, >Low1
 XH53 Limit Value NOT greater than, >High2
 XH54 Limit Value NOT smaller than, >Low2
 XH55 Limit Value NOT greater than, >High3
 XH56 Limit Value NOT smaller than, >Low3
 XH57 Limit Value NOT greater than, >High4/MAX
 XH58 Limit Value NOT smaller than, >Low4/MIN

C.8 Limit switches created from analogue signals – type "XL"

XL01 Limit Value lower than Low 1
 XL02 Limit Value lower than Low 2
 XL03 Limit Value lower than Low 3
 XL04 Limit Value lower than Low 4
 XL11 Limit Value lower than MIN
 XL51 Limit Value NOT lower than low 1
 XL52 Limit Value NOT lower than low 2
 XL53 Limit Value NOT lower than low 3
 XL54 Limit Value NOT lower than low 4
 XL61 Limit Value NOT lower than MIN

C.9 System acknowledge – type "XM"

XM01 Torque blocking opening

XM02	Torque blocking closing
XM03	Run time error
XM04	Position error valve/Damper
XM05	Run-time error opening
XM06	Run-time error closing
XM07	Position error open
XM08	Position error closed
XM11	Tip control 1
XM12	Tip control 2
XM13	Tip control 3
XM14	Tip control 4
XM26	Analogue signal OK
XM28	Binary signal OK
XM29	Operator blocked
XM41	External error
XM42	General error
XM46	Error
XM47	position control error
XM50	1 out of N error
XM51	2 out of N error
XM60	Correction calculation error
XMnn	System check from DCS system

C.10 Binary signals – type "XN"

XN07	Position error open local
XN08	Position error closed local
XN17	Position error open from emergency action
XN18	Position error close from emergency action
XNnn	Binary Signals free for use

C.11 Analogue value – type "XQ"

XQ01	Analogue measurement
XQ41	Operating time
XQ42	Amount counter

XQ43 Time mean value

XQ44 Electric work

C.12 Sequence control – type "XS"

XS010 Step 010 in Start-Sequence

XS020 Step 020 in Start-Sequence

XS030 Step 030 in Start-Sequence

XS040 Step 040 in Start-Sequence

XS050 Step 050 in Start-Sequence

XS060 Step 060 in Start-Sequence

XS070 Step 070 in Start-Sequence

XS080 Step 080 in Start-Sequence

XS090 Step 090 in Start-Sequence

XS100 Step 100 in Start-Sequence

XS490 Step 490 - last step in Start-Sequence. The Function Group is IN

XS510 Step 510 in Stop-Sequence

XS520 Step 520 in Stop-Sequence

XS530 Step 530 in Stop-Sequence

XS540 Step 540 in Stop-Sequence

XS550 Step 550 in Stop-Sequence

XS560 Step 560 in Stop-Sequence

XS570 Step 570 in Stop-Sequence

XS580 Step 580 in Stop-Sequence

XS590 Step 590 in Stop-Sequence

XS600 Step 600 in Stop-Sequence

XS990 Step 990 - last step in Stop-sequence. The Function Group is OUT

XSnn Step nnn in Sequence control

C.13 Combined signals – type "XU"

XU01- Free to use

XU99 Free to use

C.14 FAIL SAFE signals – type "XV"

XV01- Free to use

XV99 Free to use

C.15 Signal origin (output values HW & SW) – type "Yx"

YA	Automatic
YB	Single unit control
YC	Regulation
YG	Limit values, binary (contacts)
YH	Limit values, analogue
YJ	Analog values - regulation
YL	Desks and tables
YM	Fault signals
YP	Process computer
YQ	Analog signals
YU	Combined signals
YV	Fail Safe signals

C.16 Main group Y - signal key

YA	Automatic
YB	Single unit control
YB01	Command START/IN/OPEN/FORWARD
YB02	Command STOP/OUT/CLOSE
YB03	Command RELEASE LOCAL
YB04	Command DISP.
YB05	Command DISP.
YB06	Command RESET/ACKNOWLEDGE
YB11	Command Emergency START/ IN / OPEN
YB12	Command Emergency STOP / OUT / CLOSE
YB21	Command Release ON for START/ IN/ OPEN
YB22	Command Release ON for STOP/ OUT/ CLOSE
YC	Controller signals
YC11	Controller output 0 - 100 %
YG	Limit values, binary (contacts)

YH	Limit values, analogue
YJ	Analog values - regulation
YM	Fault signals
YQ	Analog signals (0 - 100 %)

Annex D Letter codes for process variables and control functions

Letter codes for process variables and control functions are based on ISO 15519-2, with following additions:

Process variables	N	Power output (heat)
	Y	Vibration
Modifiers	Q	Summation

	Process variable	Modifier	Control functions	Modifier
A	Electric voltage		Alarming, message [20]	
B				
C	Electric current		Control (closed loop control)	
D	Density	Difference [11]		
E	Electric or electromagnetic variables (except A and C) [1]			
F	Flow rate			
G	Distance, position or length			
H	Human observation [2]			High [30]
I	Not to be used		Indicating	
J	Power, energy			
K	Time			
L	Level [3]			Low [31]
M	Moisture, humidity			
N	Power output (heat)			
O	Not to be used			
P	Pressure, vacuum [3]	Test point [12]		
Q	Quality [4]	Summation		
R	Radiation [5]		Recording	
S	Speed, frequency [6]		Switching (open loop control)	
T	Temperature			
U	Multivariable [7]			
V				
W	Weight, force			
X				
Y	Vibration			
Z	Number of events, quantity [8]		Switching (open-loop) Safety / protection relevant ²¹	

- [1] E.g. resistance, impedance, inductance.
- [2] Based on one or more human sensory systems
- [3] When a differential pressure measurement is used for level measurement then letter code L shall be used and not P.
- [4] The measured variable shall be indicated outside the circle, specifying the type of quality, e.g. pH-value, purity, conductivity, material property, viscosity, etc.
- [5] Radiation, light, nuclear

- [6] Including vibration, rotary speed.
- [7] The generated variable shall be indicated outside the circle specifying the type of multivariable, e.g. general alarm, enthalpy, pH, μS
- [8] The letter Z as measured variable shall be used when control or monitoring responses are event-driven as opposed to time or time schedule-driven. The letter may also signify presence or state.
- [11] Indication of that the measurement represents the difference of two measurements, e.g. differential pressure over a filter
- [12] Indication of a not used measuring point, to which it is possible to connect a temporary measuring device, e.g. pressure transmitter.
- [20] Shall only be used for separate alarm control functions. If control functions S and Z at time of action also trigger an alarm / message, then the A must not be used in addition to the in front letter codes S or Z
- [21] A control function to be realized by a safety instrumented function according to IEC 61511-1 or an equipment protection system, when an acknowledgement is specified to enable a restart
- [30] Indication of that the measured value is high compared to low. The modifier can be differentiated by doubling or tripling e.g. HH -Very high, HHH - Extremely high.
- [31] Indication of that the measured value is low compared to high, The modifier can be differentiated by doubling or tripling e.g. LL - Very low, LLL - Extremely low.